

**A.BALASUBRAMANIAN.,B.E.,M.Sc,Msc (P&M) M.I.E.,F.I.V.,C.Engg,M.I.C.I.,F.I.A.S.E**

ISO Certified Valuer, Registered Valuer Income Tax Govt of India- Category-I,

**Structural Engineer, International Valuer ( IBBI No.11901)**

**Gen.Secretary Panel Engineer's Association, Tamilnadu State**

Panel Valuer – Union Bank of India, State Bank of India, HUDCO (Delhi)

(Tamilnadu & Puduchery Regions), Canara Bank & Punjab National Bank

H.R.& C.E. Panel Engineer- Govt of Tamilnadu, TAICO Bank,

**Treasurer PVAI-Tamilnadu & Kerala State Centres**

Member Engineering Council of India, Life Member Indian Concrete Institute,

Class-1A (any amount) Panel Engineer to issue Structural Stability Certificate

For Sivaganga, Madurai, Ramanathapuram, Pudukkottai & Dindigul Districts

**AL-MUNAWARA ISLAMIC SCHOOL ( CBSE)**

**Indra Nagar, Perungudi Village, Tirumayam Taluk  
Pudukkottai District**

**PERIOD OF VALIDITY :** 18.05.2023 to 17.05.2026 ( 3 Years)

Res: 49, Muneeswaran Koil street, Karaikudi-630 001, Land Line : 04565-237183 & 237185,

**Office Location :** Lat 10°04' 1.7188" N, Long 78°45' 48.8531" E

**Mobile : 9442237183/9384446180**

**Branches: 162, Thandeeswarar Illam, Sethupathy Street, Jaihindupuram, Madurai-625 011**

Tel : 0452- 2672346, Chennai –Plot No.38A,Vinay Flats Ist cross street, Kuberan Nagar Extn,  
Madippakkam, Chennai- 600 091

E mail ID- balavaluerkkdi @ gmail.com

[illegible]



THE SCHEDULE  
FORM-A

(Form of application under Sub-Section (1) Sub-Section (2) of Section 4 of the Tamilnadu Public Buildings (Licensing) Act 1965.(Madras Act XIII of 1965) referred to in Rule 3 of the TamilNadu Public Buildings (Licensing) Rules 1996)

From

The Secretary/Correspondent  
Al-Munawara Islamic School (CBSE)  
S.F. No.1014/1,3,5,8,  
Door No.624, Indra Nagar  
Perungudi Village,  
Tirumayam Taluk  
Pudukkottai District

To

The Competent Authority  
The Thasildhar  
Tirumayam

Sir

I intend to use the building/to continue to use the existing Public building not at present used as a public building which is situated in the site S.F.No.1014/1,3,5,8, North of Madurai to PDK Road, Perungudi ,in the ward or division /village/district of PUDUKKOTTAI and specified in the statement enclosed as a public building for a period of 3 years and from the 18.05.2023 to 17.05.2026

2. The year of Construction and the present approximate Cost of Construction  
\*And the purpose for which it is to be used or is being used as a Public bldgs  
Are also furnished in the statement accompanying this application.
3. I enclose a Chelan for Rs.1000/
4. I also enclose Certificate of Structural soundness in the prescribed form  
Furnished by the Engineer Shri.A.BALASUBRAMANIAN-PANEL ENGINEER  
\*GRADE-IA (Any amount), Approved by PUDUKKOTTAI District Collector thro  
Proceedings No.B1/44729/2005.

Signature of the owner of the bldg

Date :

Enclosures: 1. Statement  
2. Original Chelan for Rs. 1000/-Towards the application fee.




## ANNEXURE TO FORM-B

(Statement to accompany the Certificate of structural soundness)

- |     |  |   |
|-----|--|---|
| 01. | Location of the building<br>Door No, Street No and<br>Name of Place          | : Al-Munawara Islamic School<br>: (CBSE)<br>: S.F.No.1014/1,3,5,8<br>: Door No.624, Indra Nagar<br>: Perungudi Village<br>: Tirumayam Taluk<br>: Pudukkottai District |
| 02. | Number, Age of the Building  | : One , 09 years  |
| 03. | Short Description of structures<br>Steel/RCC framed or Load<br>Bearing walls | : RCC Framed Walls  |
| 04. | Purpose for which the Building is<br>Certified for use                       | : To run an Islamic school(CBSE)  |
| 05. | The Period for which the building<br>Will be structurally sound              | : 3 years   |
| 06. | Number of Persons to be<br>Accommodated                                      | : 500 students.   |
| 07. | Remarks  | : Ground floor stage only<br>: Completed. Form E & Declaration<br>: Hereby attached<br>: First floor under construction not<br>: Considered                           |

Date : 16.06.2023



Signature of the Engineer

**A. BALASUBRAMANIAN, B.E., M.I.E.,**  
**CHARTERED ENGINEER & PANEL ENGINEER GRADE - 1A**  
**PUDUKKOTTAI DISTRICT**  
**40, Munneswaran Kail Street,**  
**KARAIKUDI - 630 001. Mob : 9442237103**

FORM-B

(Form of Certificate of structural Soundness under Sub-Section (4) of the Section 4 of the Tamilnadu Public Buildings (Licensing) Act 1965 (TamilNadu Act 13 of 1965 referred to in rule 4 of the TamilNadu Public Buildings (Licensing) Rules 1966.)

I certify that I have inspected the building, mentioned in the statement and furnish below the salient technical features.

1. Foundation :

- i. Depth below Ground Level : 450 Cm
- ii. Nature of Soil met with at foundation level : Fine clay with sand
- iii. Pressure at Foundation : 09.00 T/sqm  
: (all Piles)
- iv. Probable SBC of the treatment met with  
At foundation level. : 20.00 T/sqm

2. Superstructure :

- i. Max.stress in the most critical section of

Masonry : 23.50 Kg/sqcm  
Concrete : 33.00 Kg/sqcm

- ii. Nature of masonry and Concrete and its  
Safe permissible stresses

Masonry : 35.00 Kg/sqcm  
Concrete : 150.00 Kg/sqcm

The structural soundness of the building has been verified by me with reference to ISI Loading Standards 875 (Latest Version) and other relevant Indian Standards Code of Practice and I Declare that the Building is structurally Sound to be used as a Public Building for the purpose noted in the statement. A license may be granted for the period of 3 years from the 18.05.2023 to the 17.05.2026 inclusive of this date.

Signature of the Engineer.

**A. BALASUBRAMANIAN, B.E., M.I.E.,**  
CHARTERED ENGINEER & PANEL ENGINEER GRADE - IA  
PUDUKKOTTAI DISTRICT  
49, Muneeswaran Koil Street,  
KARAIKUDI - 630 001. Mob : 9442237183

Date: 16.06.2023

FORM-C

(Form of Certificate of structural Soundness under Sub-Section (4) of the Section 4 of the Tamilnadu Public Buildings (Licensing) Act 1965 (TamilNadu Act 13 of 1965 referred to in rule 4 of the TamilNadu Public Buildings (Licensing) Rules 1966.)

I certify that I have inspected the building, mentioned in the statement and furnish below the salient technical features.

1. Foundation :

- |      |  |                                |
|------|--|--------------------------------|
| i.   | Depth below Ground Level                                       | : 450 cm                       |
| ii.  | Nature of Soil met with at foundation level                    | : Fine clay with sand          |
| iii. | Pressure at Foundation   | : 09.00 T/sqm<br>: (all Piles) |
| iv.  | Probable SBC of the treatment met with<br>At foundation level. | : 20.00 T/sqm                  |

2. Superstructure :

i. Max.stress in the most critical section of


Masonry	: 23.50 Kg/sqcm
Concrete	: 33.00 Kg/sqcm

ii. Nature of masonry and Concrete and its  
safe permissible stresses

Masonry	: 35.00 Kg/sqcm
Concrete	: 150.00 Kg/sqcm

The structural soundness of the building has been verified by me with reference to ISI Loading Standards 875 (Latest Version) and other relevant Indian Standards Code of Practice and I Declare that the Building is structurally Sound to be used as a Public Building for the purpose noted in the statement. A license may be granted for the period of 3 years from the 18.05.2023 to the 17.05.2026 inclusive of this date.

Date : 16.06.2023



Signature of the Engineer.


**A. BALASUBRAMANIAN, B.E., M.I.E.,**  
**CHARTERED ENGINEER & PANEL ENGINEER GRADE - 1A**  
**PUDUKKOTTAI DISTRICT**  
**48, Muniswaram Koil Street,**  
**KARAIKUDI - 630 001. Mob : 9442237183**



**STATEMENT TO ACCOMPANY THE OPINION REGARDING STRUCTURAL  
SOUNDNESS**

- |     |   |   |
|-----|---|---|
| 01. | Location of the building  | : Al-Munawara Islamic School  |
|     | Door No, Street No and  | : (CBSE)  |
|     | Name of Place   | : S.F.No. 1014/1,3,5,8  |
|     |   | : Door No.624, Indra Nagar  |
|     |   | : Perungudi Village   |
|     |   | : Tirumayam Taluk   |
|     |   | : Pudukkottai District  |
| 02. | Number, Age of the Building   | : One—09 years  |
| 03. | Number of Stories   | : Ground floor only considered  |
| 04. | Short Description of structures.<br>Steel/RCC framed or Load<br>Bearing walls | : RCC Framed Walls  |
| 05. | Purpose for which the Building is<br>Certified for use                        | : To run an Islamic school (CBSE)   |
| 06. | The Period for which the building<br>Will be structurally sound               | : 3 years   |
| 07. | Number of Persons to be<br>Accommodated                                       | : 500 students.   |
| 08. | Remarks   | : Part of Ground floor only<br>: Completed. Form E & Declaration<br>: Hereby attached |

Date : 16.06.2023

  
Signature of the Engineer

**A. BALASUBRAMANIAN, B.E., M.I.E.,**  
**CHARTERED ENGINEER & PANEL ENGINEER GRADE - 1A**  
**PUDUKKOTTAI DISTRICT**  
**49, Muneeswaran Koil Street,**  
**KARAIKUDI - 630 001. Mob : 9442237183**

## FORM -E

{(Form of report to be made to the competent authority by inspecting authorities or officers Appointed under other Acts Under section 28 of the Tamilnadu Public Buildings ( Licensing) Act 1965 (Madras Act XIII of 1965) referred to in rule 7 of the Tamilnadu Public Buildings (Licensing) Rules, 1966)}

1. Name and designation of inspecting authority or : A.Balasubramanian.,B.E., M.I.E,M.E.C.I  
Officer appointed or having jurisdiction under : Panel Engineer Grade-1A (any amount)  
Any other Act or Law : Pudukkottai District
2. Location of the Building inspected ( Door No. : Al-Munawara Islamic School (CBSE)  
Street Number, Name of Place ie Municipal : S.F.No.1014/1,3,5,8,Door No.624  
Corporation/Municipality/Panchayat or : Indra Nagar,Perungudi Village  
Panchayat Union/Township/Cantonment) : Tirumayam Taluk  
: Pudukkottai District
3. Date of Inspection : 12.06.2023  
: Date of issue of Certificate  
: 16.06.2023
4. Purpose for which the building is used : To run an Islamic (CBSE) School etc
5. Nature of defects noticed : Nil
6. Suggestions for rectifying defects : Given in the SSC & Declaration
7. If in a dangerous condition, immediate : Nil  
Steps recommended to be taken :

Date : 16.06.2023

Signature of the inspecting authority or  
Officer appointed or having jurisdiction

Copy to

1. P.A. to the Collector- Pudukkottai
2. R.D.O.—Pudukkottai.

**A. BALASUBRAMANIAN, B.E., M.I.E.,**  
**CHARTERED ENGINEER & PANEL ENGINEER GRADE - 1A**  
**PUDUKKOTTAI DISTRICT**  
**49, Muneeswaran Koil Street,**  
**KARAIKUDI - 630 001. Mob : 9442237183**



DECLARATION BY THE PANEL ENGINEER-1A ( Any amount)

**AL-MUNAVARA ISLAMIC SCHOOL (CBSE)  
S.F.No.1014/1,3,5,8 Door No.624, Indra Nagar,Perungudi Village  
Tirumayam Taluk,  
Pudukkottai District**

This Report does not include any eventualities caused due to natural calamities.

We hereby advise that periodical repairs and renovations shall be carried out to the Entire building Blocks regularly by every year and intimating me thro writing.

Further necessary fire fighting equipments should be kept in the premises and should be Trained for operation. If any fire accident/mishap occurs we are not held responsible.

Structural alteration/deviation should not be carried out to a part of whole building Without prior permission from the Panel Engineer..

Emergency exit to be provided as per norms.

All electrical points, wiring/Gadgets has to be checked properly and to be maintained Periodically- this competent Engineer is not held responsible for electrical defaults.

If any violation is found at a later stage after issue of this report we are not held Responsible and this report gets cancelled.

**Further this report covers the certified blocks & floors only-Legal aspects are not Considered. Technical soundness only considered other buildings not a Subject matter.**

Date : 16.06.2023



Signature of the inspecting authority

**A. DALASUBRAMANIAN, B.E., M.I.E.,  
CHARTERED ENGINEER & PANEL ENGINEER GRADE - 1A  
PUDUKKOTTAI DISTRICT  
40, Muneeswaran Koil Street,  
KARAIKUDI - 630 001. Mob : 9442237103**